



中国国家强制性产品认证证书



证书编号: 2021322315004329

认证委托人名称: ATOS S.p.A.
 认证委托人地址: via alla Piana, 57, I - 21018 Sesto Calende (VA), Italy
 生产者名称: ATOS S.p.A.
 生产者地址: via alla Piana, 57, I - 21018 Sesto Calende (VA), Italy
 生产企业名称: ATOS S.p.A.
 生产企业地址: via alla Piana, 57, I - 21018 Sesto Calende (VA), Italy

产品名称: 防爆型感应式位置传感器

系列、规格、型号: ETHA-15

标准: GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2013、
GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2021年11月22日 有效期至: 2026年11月21日

首次发证日期: 2021年11月22日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitiias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0005581



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2021322315004329

APPLICANT: ATOS S.p.A.
ADDRESS: via alla Piana, 57, I - 21018 Sesto Calende (VA), Italy
MANUFACTURER: ATOS S.p.A.
ADDRESS: via alla Piana, 57, I - 21018 Sesto Calende (VA), Italy
FACTORY: ATOS S.p.A.
ADDRESS: via alla Piana, 57, I - 21018 Sesto Calende (VA), Italy

PRODUCTNAME: Inductive transducer
SERIES,SPECIFICATION,MODEL: ETHA-15
STANDARDS: GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2013、
 GB 12476.5-2013

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:November 22, 2021 **Valid until:** November 21, 2026

Date of original certification:November 22, 2021

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

s 0005315



中国国家强制性产品认证证书



证书编号: 2021322315004329

附 件

产品名称: 防爆型感应式位置传感器

型号规格: ETHA-15

防爆标志: Ex d IIC T6 Gb,
Ex tD A21 IP66/IP67 T85°C

电气参数: 供电电压: $\pm 15\text{Vd.c.}$, 输出电压: $\pm 10\text{Vd.c.}$;
最大电流: 20mA;
最大功耗: $< 1\text{W}$ 。

批 准:



上海仪器仪表自控系统检验测试所有限公司